

Architect/Engineer Specifications UL Listed

Section 13900 / 21 00 00

COVER SYSTEM FOR CONCEALMENT OF FIRE SPRINKLER SYSTEMS, PIPING, CONDUIT, WIRING AND CABLE

PART 1 - GENERAL

1.01 DESCRIPTION

- A. The soffit/cover system shall incorporate a concealed snap-lock connection, which, once assembled, renders the cover essentially irremovable with the use of ordinary tools.

1.02 SUBMITTALS

- A. Submit copies of manufacturer's specifications, installation instructions, and product data.

1.03 JOB CONDITIONS

- A. Coordinate installation soffit/cover system with all other trades.

PART 2 - PRODUCTS

2.01 MATERIAL

- A. A factory-fabricated steel cover support system with concealed surface-mounted attachment clamps, in dimensions as shown on the drawings for concealment of Fire Sprinkler Systems, Piping, HVAC, Conduit, Wiring or Cable

Approved sources:

- JG Innovations, Inc.
121 E Burbank Ave
P.O. Box 8128
Janesville, WI 53547-8128
Phone #: 888-933-2248
Fax #: 608-314-8712

- In-Ex Systems, Inc.
4473 Cavallon Way
Acworth, GA 30101
Phone #: 800-483-8201
Fax #: 678-766-8202

B. Support/Attachment Devices

1. Spring steel shield clips of the size recommended by manufacturer, for securement of the cover. Clips shall be produced from 21 Gauge minimum zinc-plated spring steel and shall have a reverse curvature design such that the clips soundly secure the soffit from easy removal. Each clip must be demonstrated as being able to resist a force of 100 lbs. uplift at the free end. Test results shall be available upon request.

C. Soffit/Cover

1. The soffit/cover shall be smooth in appearance and shall be made of 24 Gauge A60/G90 galvanized steel, with a paint grip finish and factory painted of a color to be specified by the owner's representative. The cover shall have a snap-lock interfacing with the clips such that once assembled, it is rendered virtually irremovable with the use of ordinary tools.
2. The soffit and related fittings shall be factory painted with Sherwin Williams epoxy polyester hybrid powder coating of a color to be specified by the owner's representative. Matching touch-up paint shall be supplied to the owner by the manufacturer.
3. Cover manufacturer shall be staffed with a licensed engineer having a minimum of five years experience with such systems.
4. The soffit/cover shall be sized in accordance with requirements to accommodate the specific application size as specified by the project documents, specifications and blue prints, provided to the cover manufacturer prior to bid date.
5. L-Shield soffit profile for sidewall installations and/or U-Shield soffit profile for sidewall and/or pendant installations respectively.
6. Cover joints shall be butt-joined with interlocking internal splice couplings and/or with male/female interlocking joints. External couplings will NOT be allowed.
7. Cover design shall include a roll-formed "groove" at the interfacing of the cover and the adjacent construction surface to facilitate the application of sealant/adhesive compounds and enhance the security of such compounds from dislodging.

**NOTE TO SPECIFIERS: Other options are available.*

* Stainless steel with #4 finish: 16 Gauge, 18 Gauge, 20 Gauge, and 22 Gauge

* Cold-Rolled Steel: 16 Gauge, 18 Gauge, 20 Gauge, and 22 Gauge

Finishes available with cold-rolled steel:

* Zinc-galvanized Paintgrip (treated to accept painting but not painted) of ASTM-A527 Coating Class G90.

* Zinc-galvanized Paintgrip, factory treated and factory painted in colors selected by architect from manufacturers standard colors. Custom colors available upon request.

* Zinc-galvanized Paintgrip, factory treated and factory primed, which will be compatible with paint scheduled after installation.

D. Accessories

1. The system shall include tamper-resistant end caps, prefabricated corners, wall flanges, couplings, and other items, which may be necessary to complete the system, and shall be installed in accordance with manufacturer recommendations.
2. Spare Parts - The installing contractor shall supply the owner with quantities of spare parts equal to a minimum of five percent (5%) of the total quantities of each soffit part utilized in this installation.

PART 3- EXECUTION

3.01 INSTALLATION

- A. Installation of system shall be in strict accordance with approved shop drawings and manufacturer's printed instructions.
 1. If used to conceal fire sprinkler systems, the sprinkler contractor/engineer must determine the piping and sprinkler layout, including sprinkler head locations and pipe support locations (based on pipe manufacturer's specifications). Indicate areas on drawings where cover system is to be used.
 2. Select appropriate fasteners for the substrate encountered to adequately secure the pipe and cover system.
 3. To insure that the cover is linear and snug-fitting when installed, it is imperative that its support devices are anchored squarely and firmly against the structural surface in a straight line.
 4. All penetrations to the soffit/cover system must be field cut to prevent misalignment with intended protrusion. The exceptions to this are that access doors will be factory furnished and installed and perforations, if required, for ventilation purposes will be factory perforated.
 5. Guidelines for installation of modular soffit/cover system shall be supplied by the manufacturer of said system and the installing contractor shall adhere to the manufacturer's guidelines.
 6. All field cut ends and scratches shall be "touched up" (spray or brush) with a matching paint.
 7. Manufacturer shall supply on-site installation instruction, upon installer's request, by a qualified installation instructor for a minimum of one day for the project start-up (1,500 lineal feet minimum.)
 8. The completed installation shall be visibly searched for voids between the interfacing of the cover and construction surface. Voids shall be sealed with a color matching siliconized caulk or urethane caulk.

###